

EROSION PREVENTION AND SEDIMENT CONTROL SITE INSPECTION FORM

INSPECTION DATE: 8-7-08 INSPECTOR NAME: Chris Abraham QUALIFICATIONS: CEPCET

PROJECT DATA

Project Name: Westminster Crossing Project ID: 1182.12 Permit # ~~5CR106901~~ 5CR106901

Contractor Name: C&T Backhoe

On-site Responsible Person (if applicable):

Notice of Construction Filed [X] Yes [ ] No
Pre-construction Inspection [X] Yes [ ] No
Pre-construction Conference [X] Yes [ ] No

PROJECT INITIATION

[X] Yes [ ] No Are perimeter controls installed?
[X] Yes [ ] No Are perimeter BMP's installed correctly?
[X] Yes [ ] No [ ] NA Detention/sediment basin installed as the first land disturbing activity if applicable?

EROSION PREVENTION

[X] Yes [ ] No Is construction following the phasing and sequencing plan?
[X] Yes [ ] No Are Erosion Prevention measures located in the proper places?
[X] Yes [ ] No Are Erosion Prevention measures installed correctly?
[X] Yes [ ] No Are Erosion Prevention measures protecting disturbed areas?

If Erosion Prevention measures are protecting disturbed areas, what are the types of protection:
[X] Surface Roughening [X] Outlet Protection [ ] Sodding [X] Riprap or Aggregate
[ ] Topsoiling [ ] Bench Terracing [ ] Seeding [X] Hydro-seeding
[ ] Ground Cover Plants [ ] Mulching [ ] Clearwater Diversion [ ] Stream Bank Stabilization
[ ] Temporary Stabilization [X] Berms [ ] RECPs (Rolled Erosion Control Products)
[ ] Polyacrylamide (PAM) [ ] Other
[ ] Yes [ ] No [X] NA Are drainage conveyances stabilized with vegetation and/or a channel lining if applicable?
[ ] Yes [ ] No [X] NA Are previously stabilized areas being maintained if applicable?
[ ] Yes [X] No [ ] NA Has activity on the site been temporarily ceased for 21 days or more?
[ ] Yes [ ] No [X] NA If activity has ceased for 21 days or more, have temporary stabilization measures been installed within 14 days?
[ ] Yes [X] No Photo Documentation

SEDIMENT CONTROL

[X] Yes [ ] No [ ] NA Are Sediment Control practices located properly?
[X] Yes [ ] No [ ] NA Are Sediment Control practices installed properly?
[X] Yes [ ] No [ ] NA Are all soil stockpiles adequately contained?
[X] Yes [ ] No [ ] NA Are Sediment Control measures protecting off site areas?

If Sediment Control measures are protecting off site areas, what are the types of protection:
[X] Sediment Pond [ ] Sediment Trap [X] Silt Fence [X] Ditch Check
[ ] Inlet Protection [ ] Vegetated Filter Strips [ ] Polyacrylamide Flocculates [ ] Sediment Berms/Dikes
[ ] Other
[ ] Yes [X] No Photo Documentation
[ ] Yes [X] No Are any additional Erosion Prevention or Sediment Control practices required?
[ ] Yes [X] No Are any corrective actions required to on-site or perimeter practices? If yes, fully describe in NOTES section below

**OFFSITE IMPACT**

Yes  No

Are there BMP's installed in streams or active channels?  
If Yes, have them removed unless specified on the plans and check for permits.

Yes  No

Is there evidence of work outside the limits of the approved plan?

Yes  No  N/A

Is construction being de-watered properly if applicable?

Are there off-site impacts?  Yes  No If yes, provide exact location and complete details in NOTES section below.

- |  |                               |                                  |  |                                 |
|--|-------------------------------|----------------------------------|--|---------------------------------|
| <input type="checkbox"/> Waterbody         | <input type="checkbox"/> None | <input type="checkbox"/> Minimal | <input type="checkbox"/> Needs Attention | <input type="checkbox"/> Severe |
| <input type="checkbox"/> Roadway           | <input type="checkbox"/> None | <input type="checkbox"/> Minimal | <input type="checkbox"/> Needs Attention | <input type="checkbox"/> Severe |
| <input type="checkbox"/> Adjacent Property | <input type="checkbox"/> None | <input type="checkbox"/> Minimal | <input type="checkbox"/> Needs Attention | <input type="checkbox"/> Severe |
| <input type="checkbox"/> Air/Dust          | <input type="checkbox"/> None | <input type="checkbox"/> Minimal | <input type="checkbox"/> Needs Attention | <input type="checkbox"/> Severe |
| <input type="checkbox"/> Storm Sewer       | <input type="checkbox"/> None | <input type="checkbox"/> Minimal | <input type="checkbox"/> Needs Attention | <input type="checkbox"/> Severe |

Yes  No Photo Documentation

**DOCUMENTATION BY THE PERMITTEE**

Current weather conditions: Clear

Yes  No Is there a functional rain gauge located on the project site?

Recorded rainfall since previous inspection: 0 inches

Yes  No Do the logs show inspections every 7 calendar days or every 14 days and within 24 hours of any 1/2 inch or greater storm event?

Yes  No Do EP&SC logs show that action has been taken regarding any current deficiencies?

**ENFORCEMENT ACTIVITY**

Yes  No  N/A Have the proper actions been taken regarding previous deficiencies or violations if applicable?  
What, if any, enforcement activity is required as a result of this inspection?

- No action
- Negotiated compliance
- Notice of violation
- Stop work order

Required Actions: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Compliance Date: \_\_\_\_\_

**FINAL STABILIZATION**

Yes  No Have all land disturbing activities at the site ceased?

Yes  No Are there any areas of active erosion evident?

Yes  No Is there perennial vegetative cover with a density of at least 70% of cover established for the area OR have equivalent measures such as mulches, RECPs, etc. been employed?

Follow-up inspection: \_\_\_\_\_ (date)

Yes  No Photo Documentation

**NOTES**

*Some silt fence has been filled over along lots 41-44. Also some silt fence damaged behind pond #2. Silt fence around lot #20 area not trenched in. Pond #2 area has been hydroseeded. Took some photos*